

有害物質項目(流入水)

項目	採水月日 単位	4月	5月	6月	7月	8月	9月	10月	10月*	11月*	1月	1月*	2月*	年間平均	最小表示値
		4日	9日	6日	4日	1日	7日	4日	31日	28日	10日	30日	27日		
カドミウム	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.003
シアン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.1
有機リン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.1
鉛	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.01
六価クロム	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.05
ヒ素	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.01
総水銀	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.0005
アルキル水銀	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.0005
ポリ塩化ビフェニル	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.0005
トリクロロエチレン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.01
テトラクロロエチレン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.01
ジクロロメタン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.01
四塩化炭素	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.001
1, 2-ジクロロエタン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.001
1, 1-ジクロロエチレン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.01
シス-1, 2-ジクロロエチレン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.01
1, 1, 1-トリクロロエタン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.1
1, 1, 2-トリクロロエタン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.001
1, 3-ジクロロプロペン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.001
1, 4-ジオキサン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.05
チウラム	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.006
シマジン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.003
チオベンカルブ	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.02
ベンゼン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.01
セレン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.01
硝酸性窒素、亜硝酸性窒素 及びアンモニア性窒素	mg/L	6.4	6.0	7.2	6.8	6.8	6.0	5.6	8.0	8.4	9.6	9.2	9.2	7.4	0.01
フッ素	mg/L	0.2	ND	0.1	ND	ND	0.1	ND	ND	ND	ND	ND	ND	ND	0.1
ホウ素	mg/L	0.07	0.05	0.06	0.06	0.07	0.06	0.05	0.07	0.06	0.06	0.06	0.06	0.06	0.02
ダイオキシン類	pg-TEQ/L	-	-	-	-	-	-	-	0.015	-	-	-	-	0.015	0.0001

* ND : 最小表示値未満

* 翌月分として実施

有害物質項目(放流水)

項目	採水月日 単位	4月	5月	6月	7月	8月	9月	10月	10月*	11月*	1月	1月*	2月*	年間平均	最小表示値
		4日	9日	6日	4日	1日	7日	4日	31日	28日	10日	30日	27日		
カドミウム	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.003
シアン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.1
有機リン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.1
鉛	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.01
六価クロム	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.05
ヒ素	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.01
総水銀	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.0005
アルキル水銀	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.0005
ポリ塩化ビフェニル	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.0005
トリクロロエチレン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.01
テトラクロロエチレン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.01
ジクロロメタン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.01
四塩化炭素	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.001
1, 2-ジクロロエタン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.001
1, 1-ジクロロエチレン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.01
シス-1, 2-ジクロロエチレン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.01
1, 1, 1-トリクロロエタン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.1
1, 1, 2-トリクロロエタン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.001
1, 3-ジクロロプロペン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.001
1, 4-ジオキサン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.05
チウラム	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.006
シマジン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.003
チオベンカルブ	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.02
ベンゼン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.01
セレン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.01
硝酸性窒素、亜硝酸性窒素 及びアンモニア性窒素	mg/L	5.9	5.2	5.9	5.7	5.4	5.2	5.1	6.0	6.8	6.0	6.6	6.1	5.8	0.01
フッ素	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.1
ホウ素	mg/L	0.07	0.04	0.06	0.06	0.06	0.05	0.05	0.07	0.06	0.06	0.06	0.06	0.06	0.02
ダイオキシン類	pg-TEQ/L	-	-	-	-	-	-	-	0.0002	-	-	-	-	0.0002	0.0001

* ND : 最小表示値未満

* 翌月分として実施